Air Performance

P.O. Box 86
159 Genco Drive
Hartford, AL 36344
Phone: (334) 588-0077
Fax: (334) 588-0071

PTG-217 GRILLE POSITION 2

STANDARD CONSTRUCTION

FRAME
6063-T6 Extruded Aluminum
.062" Nominal Wall Thickness

BLADES
6063-T6 Extruded Aluminum
.062" Nominal Wall Thickness
0.775" Blade Spacing

BRACE BARS

As Required NTE 16" OC

STANDARD FEATURES

- Aluminum Construction Providing High Resistance to Corrosion
- High Free Area and Low Resistance to Air Flow Air Flow Make This Ideal For PTAC Applications
- Bird and Insect Screens

OPTIONS

- Kynar Finish
- Various Frames/Adaptor Options
- Insulated & Non-Insulated Blank-Off Panels
- Blank-Off Cutouts For PTAC Unit
- Bird & Insect Screens



Plan View



Ortho View



End View

* Dimensions Determined by Unit, Model And Type

Unit Type	Unit Model No.	Specify Size					Variations
		A	B	C	D	E	